

Fluorescent & Emergency Ballasts

Supplemental Details

Project:	
Type:	Catalog #:



FLUORESCENT BALLAST:

(Suffix to Catalog Number)

- EB** - Electronic ballast, <10% THD
- EB10IS** - Electronic ballast, <10% THD, Instant Start
- EB10RS** - Electronic ballast, <10% THD, Rapid Start
- EB2** - Two electronic ballasts¹
- EBL** - Electronic ballast (Reduced light output)
- EBH** - Electronic ballast (Increased light output)
- EP** - Electronic programmed start (for T5 lamp configuration)
- DIM** - Dimming ballast (electronic)^{4,5}
- EBZ** - Cold-weather electronic ballast (0°F starting temperature)
- LTEB** - Low-temperature electronic ballast (-30°C (-22°F) starting temperature)
- RES** - Residential ballast (120V only)²
- ()** - Other (Specify ballast manufacturer's catalog number).^{3,4}

Example: -Advance #ICN-2P32-SC

¹ Single electronic ballast is standard on all fixtures, unless "EB2" option is selected.

² Available on certain models. Consult factory for more details. Not to be used for commercial applications.

³ Use this option when a specific ballast manufacturer's model number is required.

⁴ **Unless ballast brand and model number is explicitly noted, ballast brand and model will be installed per selection by Patriot Lighting.**

⁵ Consult dimmer switch manufacturer for compatibility of dimmer switch with dimming ballast.

EMERGENCY BALLASTS:

(Suffix to Catalog Number)

- EM** - Emergency battery unit, 500 lumens^{6,7}
- EM650** - Emergency battery unit, 650 lumens (for CFL lamp configurations)
- EM700** - Emergency battery unit, 700 lumens
- EM1400** - Emergency battery unit, 1,400 lumens
- CWEM** - Cold-weather emergency battery unit (0°F starting temperature)⁹
- ()** - Other (Specify actual manufacturer's catalog number).^{8,9}

Example: -Bodine #B50ColdPak

⁶ Unless otherwise specified, standard (nominal) 500 lumens unit will be used on all F32T8 lamp types.

⁷ Not available on all models. Not for use with F96T8 lamp type.

⁸ Use this option when a specific ballast manufacturer's model number is required.

⁹ **Unless ballast brand and model number is explicitly noted, ballast brand**



Manufacturer reserves the right to make changes to specifications without notice.